

ARTO Brick and California Pavers 15209 S. Broadway St. Gardena, CA 90248-1823 Phone: (310) 768-8500 Fax: (310) 768-8544

www.artobrick.com

This 3-part specification utilizes the Construction Specifications Institute (CSI) *Manual of Practice*, including *MasterFormat*., *SectionFormat*. and *PageFormat* and is a manufacturer-specific proprietary product specification using the proprietary method of specifying applicable to project specifications and masterguide specifications. Optional text is indicated by brackets []; delete optional text in final copy of specification. Specifier Notes typically precede specification text; delete notes in final copy of specification. Trade/brand names with appropriate symbols typically are used in Specifier Notes; symbols are not used in specification text. Metric conversion, where used, is soft metric conversion.

This 3-part specification specifies concrete tile manufactured by Arto Brick California Pavers. Revise section number and title below to suit project requirements, specification practices and section content. Refer to CSI *MasterFormat* for other section numbers and titles.

PART 1 GENERAL

1.01 SUMMARY

- A. Section Includes: Handmade concrete thin brick for use as flooring.
- B. Related sections:
 - 1. Division 09 Section: Concrete and Masonry Coatings
 - 2. Division 09 Section: Waterproofing Membranes

Specifier Note: Article below may be omitted when specifying manufacturer's proprietary products and recommended installation. Retain Reference Article when specifying products and installation by an industry reference standard. If retained, list standard(s) referenced in this section. Indicate issuing authority name, acronym, standard designation and title. Establish policy for indicating edition date of standard referenced. Conditions of the Contract or Division 01 References Section may establish the edition date of standards. This article does not require compliance with standard, but is merely a listing of references used. Article below should list only those industry standards referenced in this section.

1.02 REFERENCES

- A. American National Standards Institute (ANSI)
 - 1. A108/A118 American National Standards for the Installation of Ceramic Tile
- B. American Society of Testing and Materials (ASTM International)
 - 1. C33 Specification for Concrete Aggregates
 - 2. C39/C39M Test Method for Compressive Strength of Cylindrical Concrete Specimens
 - 3. C67 Test Methods for Sampling and Testing Brick and Structural Clay Tile
 - 4. C140 Test Methods for Sampling and Testing Concrete Masonry Units and Related Units
 - 5. C150 Specification for Portland Cement



- C157/C157M Test Method for Length Change of Hardened Hydraulic-Cement Mortar and Concrete
- 7. C260 Specification for Air-Entraining Admixtures for Concrete
- 8. C270 Specification for Mortar for Unit Masonry
- 9. C482 Test Method for Bond Strength of Ceramic Tile to Portland Cement Paste
- 10. C494/C494M Specifications for Chemical Admixtures for Concrete
- 11. C979 Specification for Pigments for Integrally Colored Concrete
- C1028 Standard Test Method for Determining the Static Coefficient of Friction of Ceramic Tile
 and Other Like Surfaces by the Horizontal Dynamometer Pull-Meter Method
- 13. C1116/C1116M Specification for Fiber-Reinforced Concrete
- C1353 Test Method Using the Taber Abraser for Abrasion Resistance of Dimension Stone Subjected to Foot Traffic.

1.03 SYSTEM REQUIREMENTS

- A. Performance Requirements
 - 1. Absorption (ASTM C140): Not more than 12%.
 - 2. Freeze Thaw Resistance (ASTM C67): Unaffected after 50 cycles.
 - 3. Compressive Strength (ASTM C39): Not less than 4000 psi (27,560 kPa).
 - 4. Length Change (ASTM C157): +/-0.1% max.
 - 5. Bond Strength (ASTM C482): 50 psi (0.3 MPa).
 - 6. Abrasion Resistance (ASTM C1353): 20 wear index.
 - 7. Coefficient of Friction (ASTM C1028): 0.6 dry; 0.6 wet.
 - 8. Breaking Load (ASTM C67): Minimum load 300 lbs

Specifier Note: Article below includes submittal of relevant data to be furnished by Contractor before, during or after construction. Coordinate this article with Architect's and Contractor's duties and responsibilities in Conditions of the Contract and Division 01Submittal Procedures Section.

1.04 SUBMITTALS

- A. General: Submit listed submittals in accordance with Conditions of the Contract and Division 01
 Submittal Procedures Section.
- B. Product Data: Submit product data for specified products.
- C. Shop Drawings: Indicate layout, patterns, color arrangement, perimeter conditions, junctions with dissimilar materials, control and expansion joints, thresholds, accessories and setting details.



D. Maintenance Data: Include recommended cleaning methods, cleaning materials, stain removal methods and polishes and waxes.

Specifier Note: Article below should include prerequisites, standards, limitations and criteria that establish an overall level of quality for products and workmanship for this section. Coordinate article below with Division 01 Quality Assurance Section.

E. Samples: Submit selection and verification samples of finishes, colors and textures.

1.05 QUALITY ASSURANCE

A. Qualifications

- Installer experienced in performing work of this section who has specialized in installation of work similar to that required for this project for a minimum of 5 years.
- B. Regulatory Requirements and Approvals: [Specify applicable requirements of regulatory agencies.].
 - 1. [Code agency name].
 - a. [Report or approval number].

Specifier Note: Retain paragraph below for erected assemblies (either onsite or offsite) required for review of construction, coordination of work of several sections, testing or observation of operation. Mock-ups, when accepted or approved, establish standards by which work will be judged. Coordinate below with Division 01 Quality Control (Mock-Up Requirements) Section.

- C. Mock-Ups: Install at project site a job mock-up using acceptable products and manufacturer approved installation methods. Obtain Owner's and Architect's acceptance of finish color, texture and pattern and workmanship standard(s). Comply with Division 01 Quality Control (Mock-Up Requirements) Section.
 - 1. Mock-Up Size: [Specify mock-up size.].
 - Maintenance: Maintain mock-up during construction for workmanship comparison; remove and legally dispose of mock-up when no longer required
 - 3. Incorporation: Mock-up may be incorporated into final construction upon Owner's approval.

Specifier Note: Article below should include special and unique requirements. Coordinate article below with Division 01 Product Requirements Section.

1.06 DELIVERY, STORAGE & HANDLING

- A. General: Comply with Division 01 Product Requirements Section.
- B. Ordering: Comply with manufacturer's ordering instructions and lead time requirements to avoid construction delays.
- C. Delivery: Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact.



D. Storage and Protection: Store materials protected from exposure to harmful environmental conditions and at temperature and humidity conditions recommended by the manufacturer

1.07 ENVIRONMENTAL REQUIREMENTS

- A. Install mortar, set and grout tile when surface temperature is a minimum of 50 degrees F (10 degrees C) and rising but no greater than 90 degrees F (32 degrees C).
- B. Do not install mortar, set or grout tile when inclement weather conditions are expected within 48 hours of completion.

1.08 EXTRA MATERIALS

A. Extra materials: Provide ft2 of each size, color and surface finish of tile specified.

PART 2 PRODUCTS

Specifier Note: Retain article below for proprietary method specification. Add product attributes, performance characteristics, material standards and descriptions as applicable. Use of such phrases as "or equal" or "or approved equal" or similar phrases may cause ambiguity in specifications. Such phrases require verification (procedural, legal and regulatory) and assignment of responsibility for determining "or equal" products.

2.01 TILES

Specifier Note: Paragraph below is an addition to CSI *SectionFormat* and a supplement to 3-part specificaton. Retain or delete paragraph below per project requirements and specifier's practice.

- A. Manufacturer: Arto Brick / California Pavers.
 - Contact: 15209 S. Broadway St., Gardena, CA 90248-1823; Telephone: (310) 768-8500; Fax:
 (310) 768-8544; website: www.artobrick.com.

Specifier Note: Edit Paragraph below to suit project requirements. If substitutions are permitted, edit text below. Add text to refer to Division 01 Project Requirements (Product Substitutions Procedures) Section.

B. Substitutions: No substitutions permitted.

Specifier Note: Paragraphs below list proprietary products offered by Arto Brick California Pavers. All measurements are nominal; consult manufacturer regarding exact measurements and product options. Select product characteristics required; delete characteristics not required.

2.02 TILES

- A. Style/Size
 - 1. Alvera
 - 2. Antik
 - 3. Granulated
 - 4. Norman
 - 5. Pachanga



- 6. Smooth
- 7. Standard
- 8. 49er

Specifier Note: Select color(s) below. If more than one color is selected, create color designators and coordinate with drawings.

- B. Color
 - 1. Antik Gray
 - 2. Artillo
 - 3. Artillo Café
 - 4. Beachwood Flash
 - 5. Buff
 - 6. Café Olay
 - 7. Cauqi
 - 8. Charcoal
 - 9. Charley Brown
 - 10. Chicago
 - 11. City Hall Red
 - 12. Cotto Dark
 - 13. Cotto Gold
 - 14. Desert
 - 15. Early Gray
 - 16. El Segundo
 - 17. Flagstone
 - 18. Gold
 - 19. Grey Myst
 - 20. Hacienda
 - 21. Hacienda Flash
 - 22. Hancock
 - 23. Hermosa Blend
 - 24. Jose Gray
 - 25. Lopez Brown



CONCRETE THIN BRICK FLOORING 09 30	33 CMARIO
26. Los Angeles	
27. Metro	
28. Mission Red	
29. Natural Gray	
30. Normandy Cream	
31. Ocean Green	
32. Old California	
33. Plumish	
34. Red Flash	
35. Rice	
36. Rosa	
37. Rosa White Wash	
38. Sangria	
39. Santa Monica	
40. Sidewalk Gray	
41. Smoke	
42. Sonora Sunset	
43. Tuscan Mustard	
44. Urban	
45. Used Desert	
46. Used Red	
Specifier Note: Refer to Arto color chart to view color options. approve color variation.	Request samples from Arto or distributor to
C. Texture	
1. Standard	
2. Acid Wash	
3. Limestone	

4. Luna

5. Sandblast

6. Travertine

7. Sand Blast



2.03 ACCESSORIES

- A. Size/Style
- B. Color
- C. Texture

Specifier Note: Indicate if color and texture specified for accessories differ from tile color and texture.

2.04 MATERIALS

A. Mortar

- 1. Thin set mortar
 - a. Useful for transitions or areas with limited clearance.
- 2. Medium bed mortar
 - a. Recommended for larger format (8x8 or larger) tiles.
- 3. Mortar bed
 - a. Traditional method used by masons.

B. Grout

- Grout with sanded Type S mortar or other sanded grout specified. Ensure grout selected is appropriate for grout joint width specified and installation location.
- Grout using a grout bag and remove excess grout once it has set up but before it has hardened. Tiles can be presealed to ease grout removal.

C. Sealer

- 1. Seal units to protect surface finish and color.
- 2. Types of sealer
 - a. Penetrating seals below surface, matte finish, breathable surface
 - a. Topical seals above surface, glossy finish, superior stain protection
- 3. Sealing recommendations
 - a. Interior applications penetrating or topical, depending on look and stain protection desired
 - a. Exterior applications penetrating only for superior durability and slip fall resistance
- D. Waterproofing membrane
 - 1. Recommended for interior applications
- E. Anti-fracture membrane

ARTO

CONCRETE THIN BRICK FLOORING 09 30 33

- 1. Can be used to bridge existing cracks or for entire slab
- F. Cleavage membrane
 - 1. Must be used with slabs cured less than 28 days

PART 3 EXECUTION

Specifier Note: Paragraph below is an addition to CSI SectionFormat and a supplement to this three-part specification. Retain or delete paragraph below per project requirements and specifier's practice.

3.01 MANUFACTURER'S INSTRUCTIONS

A. Compliance: Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions and product carton instructions for installation.

3.02 EXAMINATION

- A. Site Verification of Conditions: Verify that substrate conditions, which have been previously installed under other sections, are acceptable for product installation in accordance with manufacturer's instructions.
 - 1. Concrete slabs shall have roughened or troweled surfaces to allow for bonding.
 - 2. Ensure all substrates are clean and free of contaminants.
 - Maximum substrate variation from required plane shall be 1/8" in 10 feet or as otherwise specified.
- B. Movement joints
 - 1. Must be included per ANSI/TCA guidelines

3.03 PREPARATION

A. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.04 CLEANING

- A. Clean with water and soft nylon brushes only; do not allow mortar to set up on surfaces.
 - 1. Excessive water use may affect curing of grout and mortar bed.
- B. Do not use acid or alkali cleansers which may damage the surface of the tile.
- C. Test all products before wholesale application.

3.05 PROTECTION

- A. Protect installed products until completion of project.
- B. Repair or replace damaged products prior to Substantial Completion.

END OF SECTION